



**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

---

Attn:

**Nathanael Roberts  
TTI Environmental Inc.  
1253 North Church Street  
Moorestown, NJ 08057**

3/16/2022

Phone: (856) 840-8800  
Fax: (856) 840-8815

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 3/2/2022. The results are tabulated on the attached data pages for the following client designated project:

**21-213 / Riverside PreSchool**

The reference number for these samples is EMSL Order #012203266. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

---

Owen McKenna, Chemistry Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.  
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012203266  
 CustomerID: TTIE54  
 CustomerPO: 034375  
 ProjectID:

Attn: **Nathanael Roberts**  
**TTI Environmental Inc.**  
**1253 North Church Street**  
**Moorestown, NJ 08057**

Phone: (856) 840-8800  
 Fax: (856) 840-8815  
 Received: 3/2/2022 08:00 AM

Project: 21-213 / Riverside PreSchool

**Analytical Results**

**Client Sample Description** 1 / Pre School TCU's 704 **Collected:** 3/2/2022 6:31:00 AM **Lab ID:** 012203266-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.06	1.00 µg/L	3/15/2022 VD	3/15/2022 VD 10:46

**Client Sample Description** 2 / Pre School TCU's 703 **Collected:** 3/2/2022 6:32:00 AM **Lab ID:** 012203266-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.50	1.00 µg/L	3/15/2022 VD	3/15/2022 VD 10:51

**Client Sample Description** 3 / Pre School TCU's 702 **Collected:** 3/2/2022 6:39:00 AM **Lab ID:** 012203266-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.82	1.00 µg/L	3/15/2022 VD	3/15/2022 VD 10:53

**Client Sample Description** 4 / Pre School TCU's 701 **Collected:** 3/2/2022 6:35:00 AM **Lab ID:** 012203266-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.60	1.00 µg/L	3/15/2022 VD	3/15/2022 VD 10:54

**Definitions:**

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results



**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

---

Attn:

**Nathanael Roberts  
TTI Environmental Inc.  
1253 North Church Street  
Moorestown, NJ 08057**

3/16/2022

Phone: (856) 840-8800  
Fax: (856) 840-8815

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 3/2/2022. The results are tabulated on the attached data pages for the following client designated project:

**21-213 / Riverside Garage, Gym, Concession Stand**

The reference number for these samples is EMSL Order #012203267. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

---

Owen McKenna, Chemistry Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.  
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012203267  
 CustomerID: TTIE54  
 CustomerPO: 034375  
 ProjectID:

Attn: **Nathanael Roberts**  
**TTI Environmental Inc.**  
**1253 North Church Street**  
**Moorestown, NJ 08057**

Phone: (856) 840-8800  
 Fax: (856) 840-8815  
 Received: 3/2/2022 08:00 AM

Project: 21-213 / Riverside Garage, Gym, Concession Stand

**Analytical Results**

**Client Sample Description** 1 / Gym Building Trainer **Collected:** 3/2/2022 5:46:00 AM **Lab ID:** 012203267-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	34.3	1.00 µg/L	3/15/2022 VD	3/15/2022 VD 10:56

**Client Sample Description** 2 / Gym Building Trainer **Collected:** 3/2/2022 5:45:00 AM **Lab ID:** 012203267-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	3/15/2022 VD	3/15/2022 VD 10:57

**Client Sample Description** 3 / Gym Building Girls Locker **Collected:** 3/2/2022 5:40:00 AM **Lab ID:** 012203267-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	7.70	1.00 µg/L	3/15/2022 VD	3/15/2022 VD 10:59

**Client Sample Description** 4 / Gym Building G3 Hallway **Collected:** 3/2/2022 5:39:00 AM **Lab ID:** 012203267-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.14	1.00 µg/L	3/15/2022 VD	3/15/2022 VD 11:00

**Client Sample Description** 5 / Gym Building Boys Locker **Collected:** 3/2/2022 5:37:00 AM **Lab ID:** 012203267-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	3/15/2022 VD	3/15/2022 VD 11:05



## EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>

[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order:	012203267
CustomerID:	TTIE54
CustomerPO:	034375
ProjectID:	

### Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results



**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

---

Attn:

**Nathanael Roberts  
TTI Environmental Inc.  
1253 North Church Street  
Moorestown, NJ 08057**

3/16/2022

Phone: (856) 840-8800  
Fax: (856) 840-8815

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 3/2/2022. The results are tabulated on the attached data pages for the following client designated project:

**21-213 / Riverside Elementary School**

The reference number for these samples is EMSL Order #012203268. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

---

Owen McKenna, Chemistry Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.  
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012203268  
 CustomerID: TTIE54  
 CustomerPO: 034375  
 ProjectID:

Attn: **Nathanael Roberts**  
**TTI Environmental Inc.**  
**1253 North Church Street**  
**Moorestown, NJ 08057**

Phone: (856) 840-8800  
 Fax: (856) 840-8815  
 Received: 3/2/2022 08:00 AM

Project: 21-213 / Riverside Elementary School

**Analytical Results**

**Client Sample Description** 1 / ADA/Wall Mount **Collected:** 3/2/2022 6:00:00 AM **Lab ID:** 012203268-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	3/15/2022 VD	3/15/2022 VD 11:07

**Client Sample Description** 2 / ADA/Wall Mount **Collected:** 3/2/2022 6:01:00 AM **Lab ID:** 012203268-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	3/15/2022 VD	3/15/2022 VD 11:08

**Client Sample Description** 3 / ADA/Wall Mount **Collected:** 3/2/2022 5:56:00 AM **Lab ID:** 012203268-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	3/15/2022 VD	3/15/2022 VD 11:13

**Client Sample Description** 4 / Hand Sanation/Food **Collected:** 3/2/2022 5:57:00 AM **Lab ID:** 012203268-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	3/15/2022 VD	3/15/2022 VD 11:14

**Client Sample Description** 5 / Field Blank **Collected:** 3/2/2022 **Lab ID:** 012203268-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	3/15/2022 VD	3/15/2022 VD 11:16



## EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>

[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order:	012203268
CustomerID:	TTIE54
CustomerPO:	034375
ProjectID:	

### Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results





**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

---

Attn:

**Nathanael Roberts  
TTI Environmental Inc.  
1253 North Church Street  
Moorestown, NJ 08057**

3/16/2022

Phone: (856) 840-8800  
Fax: (856) 840-8815

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 3/2/2022. The results are tabulated on the attached data pages for the following client designated project:

**21-213 / Riverside Early Childhood Center**

The reference number for these samples is EMSL Order #012203269. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

---

Owen McKenna, Chemistry Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.  
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012203269

CustomerID: TTIE54

CustomerPO: 034375

ProjectID:

Attn: **Nathanael Roberts**  
**TTI Environmental Inc.**  
**1253 North Church Street**  
**Moorestown, NJ 08057**

Phone: (856) 840-8800  
 Fax: (856) 840-8815  
 Received: 3/2/2022 08:00 AM

Project: 21-213 / Riverside Early Childhood Center

**Analytical Results**

**Client Sample Description** 1 / 1st FI ECC 301 **Collected:** 3/2/2022 5:50:00 AM **Lab ID:** 012203269-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.27	1.00 µg/L	3/14/2022 VD	3/15/2022 VD 04:58

**Client Sample Description** 2 / 1st FI ECC 302 **Collected:** 3/2/2022 5:51:00 AM **Lab ID:** 012203269-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	3/14/2022 VD	3/15/2022 VD 05:03

**Client Sample Description** 3 / 1st FI ECC 303 **Collected:** 3/2/2022 5:52:00 AM **Lab ID:** 012203269-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.02	1.00 µg/L	3/14/2022 VD	3/15/2022 VD 05:08

**Client Sample Description** 4 / 1st FI ECC 304 **Collected:** 3/2/2022 5:53:00 AM **Lab ID:** 012203269-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	3/14/2022 VD	3/15/2022 VD 05:09

**Client Sample Description** 5 / 2nd FI ECC 401 **Collected:** 3/2/2022 6:05:00 AM **Lab ID:** 012203269-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.54	1.00 µg/L	3/14/2022 VD	3/15/2022 VD 05:11

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012203269  
 CustomerID: TTIE54  
 CustomerPO: 034375  
 ProjectID:

Attn: **Nathanael Roberts**  
**TTI Environmental Inc.**  
**1253 North Church Street**  
**Moorestown, NJ 08057**

Phone: (856) 840-8800  
 Fax: (856) 840-8815  
 Received: 3/2/2022 08:00 AM

Project: 21-213 / Riverside Early Childhood Center

**Analytical Results**

**Client Sample Description** 6 / 2nd FI ECC 402 **Collected:** 3/2/2022 6:05:00 AM **Lab ID:** 012203269-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	3/14/2022 VD	3/15/2022 VD 05:12

**Client Sample Description** 7 / 2nd FI ECC 403 **Collected:** 3/2/2022 6:07:00 AM **Lab ID:** 012203269-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	3/14/2022 VD	3/15/2022 VD 05:14

**Client Sample Description** 8 / 2nd FI ECC 404 **Collected:** 3/2/2022 6:07:00 AM **Lab ID:** 012203269-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	3/14/2022 VD	3/15/2022 VD 05:15

**Client Sample Description** 9 / 2nd FI ECC Nurse **Collected:** 3/2/2022 6:08:00 AM **Lab ID:** 012203269-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.26	1.00 µg/L	3/14/2022 VD	3/15/2022 VD 05:17

**Definitions:**

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results



**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

---

Attn:

**Nathanael Roberts  
TTI Environmental Inc.  
1253 North Church Street  
Moorestown, NJ 08057**

3/16/2022

Phone: (856) 840-8800  
Fax: (856) 840-8815

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 3/2/2022. The results are tabulated on the attached data pages for the following client designated project:

**21-213 / Riverside High - Middle School**

The reference number for these samples is EMSL Order #012203270. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

---

Owen McKenna, Chemistry Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.  
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order:	012203270
CustomerID:	TTIE54
CustomerPO:	034375
ProjectID:	

Attn: **Nathanael Roberts**  
**TTI Environmental Inc.**  
**1253 North Church Street**  
**Moorestown, NJ 08057**

Phone: (856) 840-8800  
 Fax: (856) 840-8815  
 Received: 3/2/2022 08:00 AM

Project: 21-213 / Riverside High - Middle School

**Analytical Results**

**Client Sample Description** 4 / 1st FI HS HS Nurse **Collected:** 3/2/2022 5:15:00 AM **Lab ID:** 012203270-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	3/14/2022 VD	3/15/2022 VD 04:07

**Client Sample Description** 5 / MS Basement B01 Home Ec **Collected:** 3/2/2022 5:00:00 AM **Lab ID:** 012203270-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.46	1.00 µg/L	3/14/2022 VD	3/15/2022 VD 04:15

**Client Sample Description** 6 / MS Basement B01 Home Ec **Collected:** 3/2/2022 5:00:00 AM **Lab ID:** 012203270-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	3.16	1.00 µg/L	3/14/2022 VD	3/15/2022 VD 04:16

**Client Sample Description** 7 / MS Basement B01 Home Ec **Collected:** 3/2/2022 5:01:00 AM **Lab ID:** 012203270-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.13	1.00 µg/L	3/14/2022 VD	3/15/2022 VD 04:18

**Client Sample Description** 8 / MS Basement B01 Home Ec **Collected:** 3/2/2022 5:01:00 AM **Lab ID:** 012203270-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	3/14/2022 VD	3/15/2022 VD 04:19

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012203270

CustomerID: TTIE54

CustomerPO: 034375

ProjectID:

Attn: **Nathanael Roberts**  
**TTI Environmental Inc.**  
**1253 North Church Street**  
**Moorestown, NJ 08057**

Phone: (856) 840-8800  
 Fax: (856) 840-8815  
 Received: 3/2/2022 08:00 AM

Project: 21-213 / Riverside High - Middle School

**Analytical Results**

**Client Sample Description** 9 / MS Basement B01 Home Ec **Collected:** 3/2/2022 5:02:00 AM **Lab ID:** 012203270-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.24	1.00 µg/L	3/14/2022 VD	3/15/2022 VD 04:21

**Client Sample Description** 10 / MS Basement B01 Home Ec **Collected:** 3/2/2022 5:03:00 AM **Lab ID:** 012203270-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.59	1.00 µg/L	3/14/2022 VD	3/15/2022 VD 04:23

**Client Sample Description** 17 / HS Basement HS Cafe **Collected:** 3/2/2022 5:10:00 AM **Lab ID:** 012203270-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.45	1.00 µg/L	3/14/2022 VD	3/15/2022 VD 04:24

**Client Sample Description** 18 / HS Basement HS Cafe **Collected:** 3/2/2022 5:10:00 AM **Lab ID:** 012203270-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.04	1.00 µg/L	3/14/2022 VD	3/15/2022 VD 04:26

**Client Sample Description** 19 / HS Basement HS Cafe **Collected:** 3/2/2022 5:10:00 AM **Lab ID:** 012203270-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	14.1	1.00 µg/L	3/14/2022 VD	3/15/2022 VD 04:30

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012203270  
 CustomerID: TTIE54  
 CustomerPO: 034375  
 ProjectID:

Attn: **Nathanael Roberts**  
**TTI Environmental Inc.**  
**1253 North Church Street**  
**Moorestown, NJ 08057**

Phone: (856) 840-8800  
 Fax: (856) 840-8815  
 Received: 3/2/2022 08:00 AM

Project: 21-213 / Riverside High - Middle School

**Analytical Results**

**Client Sample Description** 25 / HS Basement HS Cafe **Collected:** 3/2/2022 5:10:00 AM **Lab ID:** 012203270-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	3/14/2022 VD	3/15/2022 VD 04:32

**Client Sample Description** 1B / MS Basement B38 Hall **Collected:** 3/2/2022 4:46:00 AM **Lab ID:** 012203270-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	3/14/2022 VD	3/15/2022 VD 04:36

**Client Sample Description** 15B / HS Basement B08 Hall **Collected:** 3/2/2022 4:48:00 AM **Lab ID:** 012203270-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	3/14/2022 VD	3/15/2022 VD 04:38

**Client Sample Description** 16B / 1st Floor HS Media **Collected:** 3/2/2022 4:50:00 AM **Lab ID:** 012203270-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	3/14/2022 VD	3/15/2022 VD 04:40

**Client Sample Description** 14B / 1st Floor HS 122 Hall **Collected:** 3/2/2022 5:03:00 AM **Lab ID:** 012203270-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	3/14/2022 VD	3/15/2022 VD 04:41

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012203270

CustomerID: TTIE54

CustomerPO: 034375

ProjectID:

Attn: **Nathanael Roberts**  
**TTI Environmental Inc.**  
**1253 North Church Street**  
**Moorestown, NJ 08057**

Phone: (856) 840-8800  
 Fax: (856) 840-8815  
 Received: 3/2/2022 08:00 AM

Project: 21-213 / Riverside High - Middle School

**Analytical Results**

**Client Sample Description** 2B / 1st Floor HS 112 Hall **Collected:** 3/2/2022 5:07:00 AM **Lab ID:** 012203270-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	3/14/2022 VD	3/15/2022 VD 04:43

**Client Sample Description** 26B / 228 Hallway **Collected:** 3/2/2022 5:15:00 AM **Lab ID:** 012203270-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	3/14/2022 VD	3/15/2022 VD 04:44

**Client Sample Description** 27B / 230 Hallway **Collected:** 3/2/2022 5:17:00 AM **Lab ID:** 012203270-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	3/14/2022 VD	3/15/2022 VD 04:49

**Client Sample Description** 28B / 212 Hallway **Collected:** 3/2/2022 5:18:00 AM **Lab ID:** 012203270-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	3/14/2022 VD	3/15/2022 VD 04:50

**Client Sample Description** 29 / 211 Hallway **Collected:** 3/2/2022 5:20:00 AM **Lab ID:** 012203270-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	3/14/2022 VD	3/15/2022 VD 04:52



**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012203270  
 CustomerID: TTIE54  
 CustomerPO: 034375  
 ProjectID:

Attn: **Nathanael Roberts**  
**TTI Environmental Inc.**  
**1253 North Church Street**  
**Moorestown, NJ 08057**

Phone: (856) 840-8800  
 Fax: (856) 840-8815  
 Received: 3/2/2022 08:00 AM

Project: 21-213 / Riverside High - Middle School

**Analytical Results**

**Client Sample Description** 30B / 202 Hallway **Collected:** 3/2/2022 5:23:00 AM **Lab ID:** 012203270-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	3/14/2022 VD	3/15/2022 VD 05:18

**Client Sample Description** 3B / MS 103 Hallway **Collected:** 3/2/2022 5:00:00 AM **Lab ID:** 012203270-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	3/14/2022 VD	3/15/2022 VD 05:20

**Client Sample Description** 11B / MS 111 Hallway **Collected:** 3/2/2022 4:53:00 AM **Lab ID:** 012203270-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	3/14/2022 VD	3/15/2022 VD 05:31

**Client Sample Description** 12B / MS 104 Hallway **Collected:** 3/2/2022 4:54:00 AM **Lab ID:** 012203270-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	3/14/2022 VD	3/15/2022 VD 05:32

**Definitions:**

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results



**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

---

Attn:

**Nathanael Roberts  
TTI Environmental Inc.  
1253 North Church Street  
Moorestown, NJ 08057**

6/20/2022

Phone: (856) 840-8800  
Fax: (856) 840-8815

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 6/15/2022. The results are tabulated on the attached data pages for the following client designated project:

**21-213 / Riverside School District**

The reference number for these samples is EMSL Order #012209375. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

---

Owen McKenna, Chemistry Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.  
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012209375  
 CustomerID: TTIE54  
 CustomerPO: 034375  
 ProjectID:

Attn: **Nathanael Roberts**  
**TTI Environmental Inc.**  
**1253 North Church Street**  
**Moorestown, NJ 08057**

Phone: (856) 840-8800  
 Fax: (856) 840-8815  
 Received: 6/15/2022 09:00 AM

Project: 21-213 / Riverside School District

**Analytical Results**

**Client Sample Description** 01/Trainer Hose Bib **Collected:** 6/14/2022 7:20:00 AM **Lab ID:** 012209375-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	84.9	1.00 µg/L	6/16/2022 VD	6/16/2022 VD 15:32

**Client Sample Description** 02/Football Hut Hose Bib **Collected:** 6/14/2022 7:26:00 AM **Lab ID:** 012209375-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	30.4	1.00 µg/L	6/15/2022 VD	6/16/2022 JW 16:13

**Client Sample Description** 03/Concession Stand Sink **Collected:** 6/14/2022 7:30:00 AM **Lab ID:** 012209375-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	8.00	1.00 µg/L	6/16/2022 VD	6/16/2022 VD 15:33

**Definitions:**

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results